



## **Certificate of conformity**

Registration No. : ATSZAEK180425007-01

Report No. : SZAEK180425007-01

**Applicant** : **AOK LED Light Company Limited** 

**Address**: Building 1, St George's Science and Technology

Industrial Park, Shajin Street, Shenzhen, Guangdong

Province, China Zip 518125

Product : LED Flood Light

Model : AOK-200Wi, AOK-40Wi, AOK-80Wi, AOK-120Wi,

AOK-160Wi, AOK-240Wi, AOK-280Wi

Trademark : // K

**Test method** : **IEC 62262:2002** 

According to IEC 62262:2002 Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code), to test the sample, the sample test results as follows:

Pass through the IK10 test, Comply with the requirements of IEC 62262:2002 Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code).

**IK 10** 

2018-04-27 Date Wike Diana

erifier signature

Manager

**Shenzhen Anbotek Compliance Laboratory Limited** 

Address:East of 4/F,Building A, Hourui No.3 Industrial Zone, Xixiang Street,Bao' an District,Shenzhen, Guangdong,China

Tel:(86)755-26066061 Fax:(86)755-26066021 Email:service@anbotek.com